

FEDERAL OPERATING PERMIT

A FEDERAL OPERATING PERMIT IS HEREBY ISSUED TO
National Aeronautics and Space Administration

AUTHORIZING THE OPERATION OF
Lyndon B. Johnson Space Center
Space Research and Technology

LOCATED AT
Harris County, Texas
Latitude 29° 33' 28" Longitude 95° 5' 12"
Regulated Entity Number: RN100665579

This permit is issued in accordance with and subject to the Texas Clean Air Act (TCAA), Chapter 382 of the Texas Health and Safety Code and Title 30 Texas Administrative Code Chapter 122 (30 TAC Chapter 122), Federal Operating Permits. Under 30 TAC Chapter 122, this permit constitutes the permit holder's authority to operate the site and emission units listed in this permit. Operations of the site and emission units listed in this permit are subject to all additional rules or amended rules and orders of the Commission pursuant to the TCAA.

This permit does not relieve the permit holder from the responsibility of obtaining New Source Review authorization for new, modified, or existing facilities in accordance with 30 TAC Chapter 116, Control of Air Pollution by Permits for New Construction or Modification.

The site and emission units authorized by this permit shall be operated in accordance with 30 TAC Chapter 122, the general terms and conditions, special terms and conditions, and attachments contained herein.

This permit shall expire five years from the date of issuance. The renewal requirements specified in 30 TAC § 122.241 must be satisfied in order to renew the authorization to operate the site and emission units.

Permit No: O1552 Issuance Date: January 20, 2016

For the Commission

Table of Contents

Section	Page
General Terms and Conditions	1
Special Terms and Conditions	1
Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting.....	1
Additional Monitoring Requirements	8
New Source Review Authorization Requirements.....	9
Compliance Requirements	10
Protection of Stratospheric Ozone	11
Permit Location.....	12
Permit Shield (30 TAC § 122.148)	12
Attachments.....	13
Applicable Requirements Summary.....	14
Additional Monitoring Requirements	80
Permit Shield	98
New Source Review Authorization References	102
Appendix A	110
Acronym List	111

General Terms and Conditions

The permit holder shall comply with all terms and conditions contained in 30 TAC § 122.143 (General Terms and Conditions), 30 TAC § 122.144 (Recordkeeping Terms and Conditions), 30 TAC § 122.145 (Reporting Terms and Conditions), and 30 TAC § 122.146 (Compliance Certification Terms and Conditions).

In accordance with 30 TAC § 122.144(1), records of required monitoring data and support information required by this permit, or any applicable requirement codified in this permit, are required to be maintained for a period of five years from the date of the monitoring report, sample, or application unless a longer data retention period is specified in an applicable requirement. The five year record retention period supersedes any less stringent retention requirement that may be specified in a condition of a permit identified in the New Source Review Authorization attachment.

If the permit holder chooses to demonstrate that this permit is no longer required, a written request to void this permit shall be submitted to the Texas Commission on Environmental Quality (TCEQ) by the Responsible Official in accordance with 30 TAC § 122.161(e). The permit holder shall comply with the permit's requirements, including compliance certification and deviation reporting, until notified by the TCEQ that this permit is voided.

The permit holder shall comply with 30 TAC Chapter 116 by obtaining a New Source Review authorization prior to new construction or modification of emission units located in the area covered by this permit.

All reports required by this permit must include in the submittal a cover letter which identifies the following information: company name, TCEQ regulated entity number, air account number (if assigned), site name, area name (if applicable), and Air Permits Division permit number(s).

Special Terms and Conditions:

Emission Limitations and Standards, Monitoring and Testing, and Recordkeeping and Reporting

1. Permit holder shall comply with the following requirements:
 - A. Emission units (including groups and processes) in the Applicable Requirements Summary attachment shall meet the limitations, standards, equipment specifications, monitoring, recordkeeping, reporting, testing, and other requirements listed in the Applicable Requirements Summary attachment to assure compliance with the permit.
 - B. The textual description in the column titled "Textual Description" in the Applicable Requirements Summary attachment is not enforceable and is not deemed as a substitute for the actual regulatory language. The Textual Description is provided for information purposes only.
 - C. A citation listed on the Applicable Requirements Summary attachment, which has a notation [G] listed before it, shall include the referenced section and subsection for all commission rules, or paragraphs for all federal and state regulations and all subordinate paragraphs, subparagraphs and clauses, subclauses, and items contained within the referenced citation as applicable requirements.

- D. When a grouped citation, notated with a [G] in the Applicable Requirements Summary, contains multiple compliance options, the permit holder must keep records of when each compliance option was used.
 - E. Emission units subject to 40 CFR Part 63, Subparts ZZZZ and WWWW as identified in the attached Applicable Requirements Summary table are subject to 30 TAC Chapter 113, Subchapter C, § 113.1090 and § 113.1500, respectively, which incorporate the 40 CFR Part 63 Subparts by reference.
 - F. For the purpose of generating emission reduction credits through 30 TAC Chapter 101, Subchapter H, Division 1 (Emission Credit Banking and Trading), the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 101.302 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.303 (relating to Emission Reduction Credit Generation Certification)
 - (iii) Title 30 TAC § 101.304 (relating to Mobile Emission Reduction Credit Generation and Certification)
 - (iv) Title 30 TAC § 101.309 (relating to Emission Credit Banking and Trading)
 - (v) The terms and conditions by which the emission limits are established to generate the reduction credit are applicable requirements of this permit
 - G. The permit holder shall comply with the following 30 TAC Chapter 101, Subchapter H, Division 3 (Mass Emission Cap and Trade Program) Requirements:
 - (i) Title 30 TAC § 101.352 (relating to General Provisions)
 - (ii) Title 30 TAC § 101.353 (relating to Allocation of Allowances)
 - (iii) Title 30 TAC § 101.354 (relating to Allowance Deductions)
 - (iv) Title 30 TAC § 101.356 (relating to Allowance Banking and Trading)
 - (v) Title 30 TAC § 101.358 (relating to Emission Monitoring and Compliance Demonstration)
 - (vi) Title 30 TAC § 101.359 (relating to Reporting)
 - (vii) Title 30 TAC § 101.360 (relating to Level of Activity Certification)
 - (viii) The terms and conditions by which the emission limits are established to meet or exceed the cap are applicable requirements of this permit
2. The permit holder shall comply with the following sections of 30 TAC Chapter 101 (General Air Quality Rules):
- A. Title 30 TAC § 101.1 (relating to Definitions), insofar as the terms defined in this section are used to define the terms used in other applicable requirements
 - B. Title 30 TAC § 101.3 (relating to Circumvention)

- C. Title 30 TAC § 101.8 (relating to Sampling), if such action has been requested by the TCEQ
 - D. Title 30 TAC § 101.9 (relating to Sampling Ports), if such action has been requested by the TCEQ
 - E. Title 30 TAC § 101.10 (relating to Emissions Inventory Requirements)
 - F. Title 30 TAC § 101.201 (relating to Emission Event Reporting and Recordkeeping Requirements)
 - G. Title 30 TAC § 101.211 (relating to Scheduled Maintenance, Start-up, and Shutdown Reporting and Recordkeeping Requirements)
 - H. Title 30 TAC § 101.221 (relating to Operational Requirements)
 - I. Title 30 TAC § 101.222 (relating to Demonstrations)
 - J. Title 30 TAC § 101.223 (relating to Actions to Reduce Excessive Emissions)
3. Permit holder shall comply with the following requirements of 30 TAC Chapter 111:
- A. Visible emissions from stationary vents with a flow rate of less than 100,000 actual cubic feet per minute and constructed either before or after January 31, 1972 that are not listed in the Applicable Requirements Summary attachment for 30 TAC Chapter 111, Subchapter A, Division 1 , shall not exceed 20% opacity averaged over a six minute period. The permit holder shall comply with the following requirements for stationary vents at the site subject to this standard:
 - (i) Title 30 TAC § 111.111(a)(1)(B) (relating to Requirements for Specified Sources)
 - (ii) Title 30 TAC § 111.111(a)(1)(E)
 - (iii) Title 30 TAC § 111.111(a)(1)(F)(i), (ii), (iii), or (iv)
 - (iv) For emission units with vent emissions subject to 30 TAC § 111.111(a)(1)(B), complying with 30 TAC § 111.111(a)(1)(F)(ii), (iii), or (iv), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146. These periodic monitoring requirements do not apply to vents that are not capable of producing visible emissions such as vents that emit only colorless VOCs; vents from non-fuming liquids; vents that provide passive ventilation, such as plumbing vents; or vent emissions from any other source that does not obstruct the transmission of light. Vents, as specified in the “Applicable Requirements Summary” attachment, that are subject to the emission limitation of 30 TAC § 111.111(a)(1)(B) are not subject to the following periodic monitoring requirements:
 - (1) An observation of stationary vents from emission units in operation shall be conducted at least once during each calendar

quarter unless the emission unit is not operating for the entire quarter.

- (2) For stationary vents from a combustion source, if an alternative to the normally fired fuel is fired for a period greater than or equal to 24 consecutive hours, the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are present. If such period is greater than 3 months, observations shall be conducted once during each quarter. Supplementing the normally fired fuel with natural gas or fuel gas to increase the net heating value to the minimum required value does not constitute creation of an alternative fuel.
- (3) Records of all observations shall be maintained.
- (4) Visible emissions observations of emission units operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of emission units operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions observations shall be made during times when the activities described in 30 TAC § 111.111(a)(1)(E) are not taking place. Visible emissions shall be determined with each stationary vent in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each stationary vent during the observation. For outdoor locations, the observer shall select a position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.
- (5) Compliance Certification:
 - (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(1) and (a)(1)(B).
 - (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(1)(F) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the

source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader.

- (c) Some vents may be subject to multiple visible emission or monitoring requirements. All credible data must be considered when certifying compliance with this requirement even if the observation or monitoring was performed to demonstrate compliance with a different requirement.

B. For visible emissions from a building, enclosed facility, or other structure; the permit holder shall comply with the following requirements:

- (i) Title 30 TAC § 111.111(a)(7)(A) (relating to Requirements for Specified Sources)
- (ii) Title 30 TAC § 111.111(a)(7)(B)(i) or (ii)
- (iii) For a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source subject to 30 TAC § 111.111(a)(7)(A), complying with 30 TAC § 111.111(a)(7)(B)(i) or (ii), and capable of producing visible emissions from, but not limited to, particulate matter, acid gases and NO_x, the permit holder shall also comply with the following periodic monitoring requirements for the purpose of annual compliance certification under 30 TAC § 122.146:
 - (1) An observation of visible emissions from a building containing an air emission source, enclosed facility, or other structure containing or associated with an air emission source which is required to comply with 30 TAC § 111.111(a)(7)(A) shall be conducted at least once during each calendar quarter unless the air emission source or enclosed facility is not operating for the entire quarter.
 - (2) Records of all observations shall be maintained.
 - (3) Visible emissions observations of air emission sources or enclosed facilities operated during daylight hours shall be conducted no earlier than one hour after sunrise and no later than one hour before sunset. Visible emissions observations of air emission sources or enclosed facilities operated only at night must be made with additional lighting and the temporary installation of contrasting backgrounds. Visible emissions shall be determined with each emissions outlet in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 mile, away from each emissions outlet during the observation. For outdoor locations, the observer shall select a

position where the sun is not directly in the observer's eyes. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor. A certified opacity reader is not required for visible emissions observations.

(4) Compliance Certification:

- (a) If visible emissions are not present during the observation, the RO may certify that the source is in compliance with the applicable opacity requirement in 30 TAC § 111.111(a)(7) and (a)(7)(A)
- (b) However, if visible emissions are present during the observation, the permit holder shall either list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2) or conduct the appropriate opacity test specified in 30 TAC § 111.111(a)(7)(B) as soon as practicable, but no later than 24 hours after observing visible emissions to determine if the source is in compliance with the opacity requirements. If an opacity test is performed and the source is determined to be in compliance, the RO may certify that the source is in compliance with the applicable opacity requirement. However, if an opacity test is performed and the source is determined to be out of compliance, the permit holder shall list this occurrence as a deviation on the next deviation report as required under 30 TAC § 122.145(2). The opacity test must be performed by a certified opacity reader

- C. Certification of opacity readers determining opacities under Method 9 (as outlined in 40 CFR Part 60, Appendix A) to comply with opacity monitoring requirements shall be accomplished by completing the Visible Emissions Evaluators Course, or approved agency equivalent, no more than 180 days before the opacity reading.
- D. For emission units with contributions from uncombined water, the permit holder shall comply with the requirements of 30 TAC § 111.111(b).
- E. Emission limits on nonagricultural processes, except for the steam generators specified in 30 TAC § 111.153, shall comply with the following requirements:
 - (i) Emissions of PM from any source may not exceed the allowable rates as required in 30 TAC § 111.151(a) (relating to Allowable Emissions Limits)
 - (ii) Sources with an effective stack height (h_e) less than the standard effective stack height (H_e), must reduce the allowable emission level by multiplying it by $[h_e/H_e]^2$ as required in 30 TAC § 111.151(b)

- (iii) Effective stack height shall be calculated by the equation specified in 30 TAC § 111.151(c)
- F. Outdoor burning, as stated in 30 TAC § 111.201, shall not be authorized unless the following requirements are satisfied:
 - (i) Title 30 TAC § 111.205 (relating to Exception for Fire Training)
 - (ii) Title 30 TAC § 111.207 (relating to Exception for Recreation, Ceremony, Cooking, and Warmth)
 - (iii) Title 30 TAC § 111.219 (relating to General Requirements for Allowable Outdoor Burning)
 - (iv) Title 30 TAC § 111.221 (relating to Responsibility for Consequences of Outdoor Burning)
- 4. For storage vessels maintaining working pressure as specified in 30 TAC Chapter 115, Subchapter B, Division 1: Storage of Volatile Organic Compounds, the permit holder shall comply with the requirements of 30 TAC § 115.112(e)(1).
- 5. Permit holder shall comply with the following 30 TAC Chapter 115, Subchapter C requirements:
 - A. When filling stationary gasoline storage vessels (Stage I) for motor vehicle fuel dispensing facilities specified in 30 TAC Chapter 115, Subchapter C, the permit holder shall comply with the following requirements:
 - (i) Title 30 TAC § 115.221 (relating to Emission Specifications)
 - (ii) Title 30 TAC § 115.222 (relating to Control Requirements)
 - (iii) Title 30 TAC § 115.223 (relating to Alternate Control Requirements)
 - (iv) Title 30 TAC § 115.224 (relating to Inspection Requirements)
 - (v) Title 30 TAC § 115.225 (relating to Testing Requirements)
 - (vi) Title 30 TAC § 115.226 (relating to Recordkeeping Requirements)
- 6. The permit holder shall comply with the following requirements for units subject to any subpart of 40 CFR Part 60, unless otherwise stated in the applicable subpart:
 - A. Title 40 CFR § 60.7 (relating to Notification and Recordkeeping)
 - B. Title 40 CFR § 60.8 (relating to Performance Tests)
 - C. Title 40 CFR § 60.11 (relating to Compliance with Standards and Maintenance Requirements)
 - D. Title 40 CFR § 60.12 (relating to Circumvention)
 - E. Title 40 CFR § 60.13 (relating to Monitoring Requirements)

- F. Title 40 CFR § 60.14 (relating to Modification)
 - G. Title 40 CFR § 60.15 (relating to Reconstruction)
 - H. Title 40 CFR § 60.19 (relating to General Notification and Reporting Requirements)
7. The permit holder shall comply with the requirements of 30 TAC Chapter 113, Subchapter C, § 113.100 for units subject to any subpart of 40 CFR Part 63, unless otherwise stated in the applicable subpart.
 8. For each gasoline dispensing facility, with a throughput of less than 10,000 gallons per month as specified in 40 CFR Part 63, Subpart CCCCCC, the permit holder shall comply with the following requirements (Title 30 TAC, Subchapter C, § 113.1380 incorporated by reference):
 - A. Title 40 CFR § 63.11111(e), for records of monthly throughput
 - B. Title 40 CFR § 63.11111(i), for compliance due to increase of throughput
 - C. Title 40 CFR § 63.11113(c), for compliance due to increase of throughput
 - D. Title 40 CFR § 63.11115(a), for operation of the source
 - E. Title 40 CFR § 63.11116(a) and (a)(1) - (4), for work practices
 - F. Title 40 CFR § 63.11116(b), for records availability
 - G. Title 40 CFR § 63.11116(d), for portable gasoline containers
 9. The permit holder shall comply with certified registrations submitted to the TCEQ for purposes of establishing federally enforceable emission limits. A copy of the certified registration shall be maintained with the permit. Records sufficient to demonstrate compliance with the established limits shall be maintained. The certified registration and records demonstrating compliance shall be provided, on request, to representatives of the appropriate TCEQ regional office and any local air pollution control agency having jurisdiction over the site. The permit holder shall submit updated certified registrations when changes at the site require establishment of new emission limits. If changes result in emissions that do not remain below major source thresholds, the permit holder shall submit a revision application to codify the appropriate requirements in the permit.

Additional Monitoring Requirements

10. The permit holder shall comply with the periodic monitoring requirements as specified in the attached "Periodic Monitoring Summary" upon issuance of the permit. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the permit holder shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. The permit holder may elect to collect monitoring data on a more frequent basis and average the data, consistent with the averaging time specified in the "Periodic Monitoring Summary," for purposes of determining whether a deviation has occurred. However, the additional data points

must be collected on a regular basis. In no event shall data be collected and used in particular instances to avoid reporting deviations. Deviations shall be reported according to 30 TAC § 122.145 (Reporting Terms and Conditions).

New Source Review Authorization Requirements

11. Permit holder shall comply with the requirements of New Source Review authorizations issued or claimed by the permit holder for the permitted area, including permits, permits by rule, standard permits, flexible permits, special permits, permits for existing facilities including Voluntary Emissions Reduction Permits and Electric Generating Facility Permits issued under 30 TAC Chapter 116, Subchapter I, or special exemptions referenced in the New Source Review Authorization References attachment. These requirements:
 - A. Are incorporated by reference into this permit as applicable requirements
 - B. Shall be located with this operating permit
 - C. Are not eligible for a permit shield
12. The permit holder shall comply with the general requirements of 30 TAC Chapter 106, Subchapter A or the general requirements, if any, in effect at the time of the claim of any PBR.
13. The permit holder shall maintain records to demonstrate compliance with any emission limitation or standard that is specified in a permit by rule (PBR) or Standard Permit listed in the New Source Review Authorizations attachment. The records shall yield reliable data from the relevant time period that are representative of the emission unit's compliance with the PBR or Standard Permit. These records may include, but are not limited to, production capacity and throughput, hours of operation, safety data sheets (SDS), chemical composition of raw materials, speciation of air contaminant data, engineering calculations, maintenance records, fugitive data, performance tests, capture/control device efficiencies, direct pollutant monitoring (CEMS, COMS, or PEMS), or control device parametric monitoring. These records shall be made readily accessible and available as required by 30 TAC § 122.144. Any monitoring or recordkeeping data indicating noncompliance with the PBR or Standard Permit shall be considered and reported as a deviation according to 30 TAC § 122.145 (Reporting Terms and Conditions).
14. The permit holder shall comply with the following requirements for Air Quality Standard Permits:
 - A. Registration requirements listed in 30 TAC § 116.611, unless otherwise provided for in an Air Quality Standard Permit
 - B. General Conditions listed in 30 TAC § 116.615, unless otherwise provided for in an Air Quality Standard Permit
 - C. Applicable requirements of 30 TAC § 116.617 for Pollution Control Projects based on the information contained in the registration application.
 - D. Requirements of the non-rule Air Quality Standard Permit for Pollution Control Projects

Compliance Requirements

15. The permit holder shall certify compliance in accordance with 30 TAC § 122.146. The permit holder shall comply with 30 TAC § 122.146 using at a minimum, but not limited to, the continuous or intermittent compliance method data from monitoring, recordkeeping, reporting, or testing required by the permit and any other credible evidence or information. The certification period may not exceed 12 months and the certification must be submitted within 30 days after the end of the period being certified.
16. Permit holder shall comply with the following 30 TAC Chapter 117 requirements:
 - A. The permit holder shall comply with the compliance schedules and submit written notification to the TCEQ Executive Director as required in 30 TAC Chapter 117, Subchapter H, Division 1:
 - (i) For sources in the Houston-Galveston-Brazoria Nonattainment area, 30 TAC § 117.9020:
 - (1) Title 30 TAC § 117.9020(2)(A), (C), and (D)
 - B. The permit holder shall comply with the Initial Control Plan unit listing requirement in 30 TAC § 117.350(c) and (c)(1).
 - C. The permit holder shall comply with the requirements of 30 TAC § 117.354 for Final Control Plan Procedures for Attainment Demonstration Emission Specifications and 30 TAC § 117.356 for Revision of Final Control Plan.
17. Use of Emission Credits to comply with applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) Offsets for Title 30 TAC Chapter 116
 - B. The permit holder shall comply with the following requirements in order to use the emission credits to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.306(c)(2)
 - (ii) The emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 1
 - (iii) The executive director has approved the use of the credit according to 30 TAC § 101.306(c)(2)

- (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.302(g) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.305 (relating to Emission Reductions Achieved Outside the United States)
- 18. Use of Discrete Emission Credits to comply with the applicable requirements:
 - A. Unless otherwise prohibited, the permit holder may use discrete emission credits to comply with the following applicable requirements listed elsewhere in this permit:
 - (i) Title 30 TAC Chapter 115
 - (ii) Title 30 TAC Chapter 117
 - (iii) If applicable, offsets for Title 30 TAC Chapter 116
 - (iv) Temporarily exceed state NSR permit allowables
 - B. The permit holder shall comply with the following requirements in order to use the credit to comply with the applicable requirements:
 - (i) The permit holder must notify the TCEQ according to 30 TAC § 101.376(d)
 - (ii) The discrete emission credits to be used must meet all the geographic, timeliness, applicable pollutant type, and availability requirements listed in 30 TAC Chapter 101, Subchapter H, Division 4
 - (iii) The executive director has approved the use of the discrete emission credits according to 30 TAC § 101.376(d)(1)(A)
 - (iv) The permit holder keeps records of the use of credits towards compliance with the applicable requirements in accordance with 30 TAC § 101.372(h) and 30 TAC Chapter 122
 - (v) Title 30 TAC § 101.375 (relating to Emission Reductions Achieved Outside the United States)

Protection of Stratospheric Ozone

- 19. Permit holders at a site subject to Title VI of the FCAA Amendments shall meet the following requirements for protection of stratospheric ozone:
 - A. Any on site servicing, maintenance, and repair on refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants or non-exempt substitutes shall be conducted in accordance with 40 CFR Part 82, Subpart F. Permit holders shall ensure that repairs on or refrigerant removal from refrigeration and nonmotor vehicle air-conditioning appliances using ozone-depleting refrigerants are performed only by properly certified technicians using certified equipment. Records shall be maintained as required by 40 CFR Part 82, Subpart F.

- B. The permit holder shall comply with 40 CFR Part 82, Subpart D related to the procurement requirements of Class I or Class II (ozone-depleting) substances or products containing those substances as specified in 40 CFR § 82.80 - § 82.86 and the applicable Part 82 Appendices.
- C. The permit holder shall comply with 40 CFR Part 82, Subpart F related to the disposal requirements for appliances using Class I or Class II (ozone-depleting) substances or non-exempt substitutes as specified in 40 CFR §§ 82.150 - 82.166 and the applicable Part 82 Appendices.

Permit Location

- 20. The permit holder shall maintain a copy of this permit and records related to requirements listed in this permit on site.

Permit Shield (30 TAC § 122.148)

- 21. A permit shield is granted for the emission units, groups, or processes specified in the attached "Permit Shield." Compliance with the conditions of the permit shall be deemed compliance with the specified potentially applicable requirements or specified potentially applicable state-only requirements listed in the attachment "Permit Shield." Permit shield provisions shall not be modified by the executive director until notification is provided to the permit holder. No later than 90 days after notification of a change in a determination made by the executive director, the permit holder shall apply for the appropriate permit revision to reflect the new determination. Provisional terms are not eligible for this permit shield. Any term or condition, under a permit shield, shall not be protected by the permit shield if it is replaced by a provisional term or condition or the basis of the term and condition changes.

Attachments

Applicable Requirements Summary

Additional Monitoring Requirements

Permit Shield

New Source Review Authorization References

Applicable Requirements Summary

Unit Summary 15

Applicable Requirements Summary 25

Note: A “none” entry may be noted for some emission sources in this permit’s “Applicable Requirements Summary” under the heading of “Monitoring and Testing Requirements” and/or “Recordkeeping Requirements” and/or “Reporting Requirements.” Such a notation indicates that there are no requirements for the indicated emission source as identified under the respective column heading(s) for the stated portion of the regulation when the emission source is operating under the conditions of the specified SOP Index Number. However, other relevant requirements pursuant to 30 TAC Chapter 122 including Recordkeeping Terms and Conditions (30 TAC § 122.144), Reporting Terms and Conditions (30 TAC § 122.145), and Compliance Certification Terms and Conditions (30 TAC § 122.146) continue to apply.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
B17GEN02	SRIC ENGINES	N/A	R7201-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B17GEN02	SRIC ENGINES	N/A	60III	40 CFR Part 60, Subpart III	No changing attributes.
B17GEN02	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B21GEN01	SRIC ENGINES	N/A	R7201-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
B21GEN01	SRIC ENGINES	N/A	60III	40 CFR Part 60, Subpart III	No changing attributes.
B21GEN01	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B24-2A	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B24-2A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
B24-2A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-B242A	30 TAC Chapter 117, Subchapter B	No changing attributes.
B24-2A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-NG	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas., SO2 Inlet Monitoring Type = No SO _x monitoring.
B24-2A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-OIL	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil., SO2 Inlet Monitoring Type = Fuel certification (or maintaining receipts)., 47C-Option = COMS exemption § 60.47c(c) for a

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					facility burning only distillate oil containing 0.5 % or less by weight sulfur and/or liquid or gaseous fuels with potential SO ₂ emission rates of no more than 26 ng/J (0.060 lb/MMBtu), no post-combustion technology
B24-3A	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B24-3A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
B24-3A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-B243A	30 TAC Chapter 117, Subchapter B	No changing attributes.
B24-3A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-NG	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas., SO2 Inlet Monitoring Type = No SO ₂ monitoring.
B24-3A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-OIL	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil., SO2 Inlet Monitoring Type = Fuel certification (or maintaining receipts)., 47C-Option = COMS exemption § 60.47c(c) for a facility burning only distillate oil containing 0.5 % or less by weight sulfur and/or liquid or gaseous fuels with potential SO ₂ emission rates of no more than 26 ng/J (0.060 lb/MMBtu), no post-combustion technology,

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
					43CE-Option = Exemption § 60.43c(e)(4), facility combusts only oil containing no more than 0.50% by weight sulfur or a mixture of 0.50% by weight sulfur oil with other fuels not subject to a PM standard under § 60.43c, not using post-combustion technology.
B24-4A	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B24-4A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
B24-4A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-B244A	30 TAC Chapter 117, Subchapter B	No changing attributes.
B24-5A	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B24-5A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	REG2	30 TAC Chapter 112, Sulfur Compounds	No changing attributes.
B24-5A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-B245A	30 TAC Chapter 117, Subchapter B	No changing attributes.
B24-5A	BOILERS/STEAM GENERATORS/STEAM	N/A	60DC-NG	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Natural gas., SO2 Inlet Monitoring Type =

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	GENERATING UNITS				No SO ₂ monitoring.
B24-5A	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	60DC-OIL	40 CFR Part 60, Subpart Dc	D-Series Fuel Type = Distillate oil., SO ₂ Inlet Monitoring Type = Fuel certification (or maintaining receipts), 47C-Option = COMS exemption § 60.47c(c) for a facility burning only distillate oil containing 0.5 % or less by weight sulfur and/or liquid or gaseous fuels with potential SO ₂ emission rates of no more than 26 ng/J (0.060 lb/MMBtu), no post-combustion technology, 43CE-Option = Exemption § 60.43c(e)(4), facility combusts only oil containing no more than 0.50% by weight sulfur or a mixture of 0.50% by weight sulfur oil with other fuels not subject to a PM standard under § 60.43c, not using post-combustion technology.
B24LOAD01	LOADING/UNLOADING OPERATIONS	N/A	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
B24TANK01A	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
B322ENG01A	SRIC ENGINES	N/A	R7ICI-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B322ENG01A	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
B322ENG01A	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B329ENG01A	SRIC ENGINES	N/A	R7ICI-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B329ENG01A	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
B329ENG01A	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B329TANK01	STORAGE TANKS/VESSELS	N/A	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
B32GEN09	SRIC ENGINES	N/A	R7201-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B32GEN09	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
B32GEN09	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B37GEN03	SRIC ENGINES	N/A	R7201-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B37GEN03	SRIC ENGINES	N/A	60IIII	40 CFR Part 60, Subpart IIII	No changing attributes.
B37GEN03	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B420BLR02	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-B420	30 TAC Chapter 117, Subchapter B	No changing attributes.
B420WOOD01	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
B421BLR01	BOILERS/STEAM GENERATORS/STEAM GENERATING UNITS	N/A	R7ICI-B421	30 TAC Chapter 117, Subchapter B	No changing attributes.
B46GEN01	SRIC ENGINES	N/A	R7201-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B46GEN01	SRIC ENGINES	N/A	60III	40 CFR Part 60, Subpart III	No changing attributes.
B46GEN01	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B48GEN01	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B48GEN02	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B48GEN03	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B7GEN02	SRIC ENGINES	N/A	R7ICI-2	30 TAC Chapter 117, Subchapter B	No changing attributes.
B7GEN02	SRIC ENGINES	N/A	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
B7GEN02	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
B9AC01	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R5122	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.
B9AC02	EMISSION POINTS/STATIONARY	N/A	R5122	30 TAC Chapter 115, Vent Gas Controls	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
	VENTS/PROCESS VENTS				
B9PAINT01	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B9PLAT	PLATING AND POLISHING OPERATIONS	N/A	63WWWWWW	40 CFR Part 63, Subpart WWWWWW	No changing attributes.
B9WOOD01	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B9WOOD02	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
B9WOOD03	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	N/A	R1111A	30 TAC Chapter 111, Visible Emissions	No changing attributes.
BSTART-1	SRIC ENGINES	N/A	R7201-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
BSTART-1	SRIC ENGINES	N/A	60III	40 CFR Part 60, Subpart III	No changing attributes.
BSTART-1	SRIC ENGINES	N/A	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPGEN	SRIC ENGINES	B10GEN02, B3GEN01, B48GEN02, B48GEN03, B9GEN01	R7ICI-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPGEN2	SRIC ENGINES	B30AGEN02, B32GEN07,	R7201-2	30 TAC Chapter 117, Subchapter B	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		B32GEN08, B37GEN04			
GRPGEN2	SRIC ENGINES	B30AGEN02, B32GEN07, B32GEN08, B37GEN04	60III	40 CFR Part 60, Subpart III	No changing attributes.
GRPGEN2	SRIC ENGINES	B30AGEN02, B32GEN07, B32GEN08, B37GEN04	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPGEN3	SRIC ENGINES	B32GEN06, B343GEN01, B48GEN01, B48GEN07, B48GEN09	R7201-3	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPGEN4	SRIC ENGINES	B15GEN01	R7201-3	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPGEN4	SRIC ENGINES	B15GEN01	63ZZZZ-1	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPGEN5	SRIC ENGINES	B25GEN02	R7201-4	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPGEN5	SRIC ENGINES	B25GEN02	60III-2	40 CFR Part 60, Subpart III	No changing attributes.
GRPGEN5	SRIC ENGINES	B25GEN02	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPGEN-B	SRIC ENGINES	B347GEN01	R7ICI-1	30 TAC Chapter 117, Subchapter B	No changing attributes.
GRPGEN-C	SRIC ENGINES	B221ENG01,	R7ICI-2	30 TAC Chapter 117,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
		B223ENG02		Subchapter B	
GRPGEN-C	SRIC ENGINES	B221ENG01, B223ENG02	60JJJJ	40 CFR Part 60, Subpart JJJJ	No changing attributes.
GRPGEN-C	SRIC ENGINES	B221ENG01, B223ENG02	63ZZZZ	40 CFR Part 63, Subpart ZZZZ	No changing attributes.
GRPTANK	STORAGE TANKS/VESSELS	B326TANK01, B48TANK01, B48TANK02	R5112	30 TAC Chapter 115, Storage of VOCs	No changing attributes.
GRPTANK2	LOADING/UNLOADING OPERATIONS	B10TANK01, B15TANK01, B17TANK01, B25TANK01, B30ATANK01, B32TANK01, B32TANK02, B32TANK03, B343TANK01, B347TANK01, B37TANK01, B37TANK02, B3TANK01, B46TANK01, B48TANK03, B48TANK04, B48TANK05, B9TANK01	R5211	30 TAC Chapter 115, Loading and Unloading of VOC	No changing attributes.
GRPTBN	EMISSION POINTS/STATIONARY VENTS/PROCESS VENTS	T-1, T-2	R1111	30 TAC Chapter 111, Visible Emissions	No changing attributes.
GRPTBN	STATIONARY TURBINES	T-1, T-2	R-7201	30 TAC Chapter 117,	No changing attributes.

Unit Summary

Unit/Group/ Process ID No.	Unit Type	Group/Inclusive Units	SOP Index No.	Regulation	Requirement Driver
				Subchapter B	
GRPTBN	STATIONARY TURBINES	T-1, T-2	60KKKK	40 CFR Part 60, Subpart KKKK	No changing attributes.

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B17GEN02	EU	R7201-2	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
B17GEN02	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						CFR 89.112(a).			
B17GEN02	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B17GEN02	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B17GEN02	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
B21GEN01	EU	R7201-1	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						road engines as specified. §117.303(a)(11)(A)-(B)			
B21GEN01	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B21GEN01	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B21GEN01	EU	60III	PM	40 CFR Part 60,	§ 60.4205(b)	Owners and operators of	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Subpart IIII	§ 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
B21GEN01	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
B24-2A	EP	R1111	OPACITY	30 TAC Chapter 111, Visible	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall	[G]§ 111.111(a)(1)(F)	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
				Emissions		not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	** See Periodic Monitoring Summary		
B24-2A	EU	REG2	SO2	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(c)	No person shall use liquid fuel with a sulfur content greater than 0.3% by weight, or allow emissions of SO2 to exceed 150 ppmv, based on 20% excess air, averaged over a 3-hour period.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
B24-2A	EU	R7ICI-B242A	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with §	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						117.320.			
B24-2A	EU	R7ICI-B242A	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B24-2A	EU	60DC-NG	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-2A	EU	60DC-NG	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						megawatts (MW).			
B24-2A	EU	60DC-NG	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-2A	EU	60DC-OIL	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(h) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
B24-2A	EU	60DC-OIL	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-2A	EU	60DC-OIL	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(a) § 60.47c(c)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(a) [G]§ 60.47c(a)(1) [G]§ 60.47c(a)(2) § 60.47c(a)(3)	§ 60.47c(a) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						average, except as specified.			
B24-3A	EP	R1111	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B24-3A	EU	REG2	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(c)	No person shall use liquid fuel with a sulfur content greater than 0.3% by weight, or allow emissions of SO ₂ to exceed 150 ppmv, based on 20% excess air, averaged over a 3-hour period.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
B24-3A	EU	R7ICI-B243A	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.8010(8)
B24-3A	EU	R7ICI-B243A	CO	30 TAC Chapter B 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B24-3A	EU	60DC-NG	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-3A	EU	60DC-NG	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).			
B24-3A	EU	60DC-NG	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-3A	EU	60DC-OIL	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(h) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
B24-3A	EU	60DC-OIL	PM	40 CFR Part 60, Subpart Dc	§ 60.43c(e)(4) § 60.40c(c) § 60.43c(d)	A facility constructed, reconstructed, or modified after February 28, 2005 and that combusts only oil that contains no more than 0.50% by weight sulfur or a mixture of 0.50% by weight sulfur oil with other fuels not subject to a PM standard under §60.43c and not using a post-combustion	§ 60.45c(a) § 60.45c(d)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						technology (except a wet scrubber) to reduce PM or sulfur dioxide emissions is not subject to the PM limit in this section.			
B24-3A	EU	60DC-OIL	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(a) § 60.47c(c)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(a) [G]§ 60.47c(a)(1) [G]§ 60.47c(a)(2) § 60.47c(a)(3)	§ 60.47c(a) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
B24-4A	EP	R1111	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B24-4A	EU	REG2	SO2	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(c)	No person shall use liquid fuel with a sulfur content greater than 0.3% by weight, or allow emissions of SO2 to exceed 150 ppmv, based on 20% excess air, averaged over a 3-hour period.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
B24-4A	EU	R7ICI-B244A	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b)	An owner or operator may not use the alternative methods specified in §§ 117.315,	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)		[G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B24-4A	EU	R7ICI-B244A	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B24-5A	EP	R1111	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B24-5A	EU	REG2	SO ₂	30 TAC Chapter 112, Sulfur Compounds	§ 112.9(c)	No person shall use liquid fuel with a sulfur content greater than 0.3% by weight, or allow emissions of SO ₂ to exceed 150 ppmv, based on 20% excess air, averaged over a 3-hour period.	§ 112.2(a) ** See Periodic Monitoring Summary	§ 112.2(c)	§ 112.2(b)
B24-5A	EU	R7ICI-B245A	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in § 117.9800 to comply with § 117.320.	[G]§ 117.8000(d)		
B24-5A	EU	R7ICI-B245A	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B24-5A	EU	60DC-NG	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-5A	EU	60DC-NG	PM	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						design heat input capacity of 2.9-29 megawatts (MW).			
B24-5A	EU	60DC-NG	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.40c(a)	This subpart applies to each steam generating unit constructed, reconstructed, or modified after 6/9/89 and that has a maximum design heat input capacity of 2.9-29 megawatts (MW).	None	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(j)
B24-5A	EU	60DC-OIL	SO ₂	40 CFR Part 60, Subpart Dc	§ 60.42c(d) § 60.40c(c) § 60.42c(h) § 60.42c(i) § 60.42c(j)	On/after the §60.8 test, oil-fired facilities shall not discharge SO ₂ gases in excess of 215 ng/J (0.50 lb/MMBtu) heat input or, alternatively, combust oil with a greater than 0.5 weight % sulfur.	§ 60.44c(h) § 60.46c(e)	[G]§ 60.48c(e) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(d) [G]§ 60.48c(e) § 60.48c(j)
B24-5A	EU	60DC-OIL	PM	40 CFR Part 60, Subpart Dc	§ 60.43c(e)(4) § 60.40c(c) § 60.43c(d)	A facility constructed, reconstructed, or modified after February 28, 2005 and that combusts only oil that contains no more than 0.50% by weight sulfur or a mixture of 0.50% by weight sulfur oil with other fuels not subject to a PM standard under §60.43c and not using a post-combustion technology (except a wet scrubber) to reduce PM or	§ 60.45c(a) § 60.45c(d)	§ 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) § 60.48c(j)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						sulfur dioxide emissions is not subject to the PM limit in this section.			
B24-5A	EU	60DC-OIL	PM (OPACITY)	40 CFR Part 60, Subpart Dc	§ 60.43c(c) § 60.40c(c) § 60.43c(d) § 60.47c(a) § 60.47c(c)	Facilities firing the specified fuels and that have heat input capacity of 8.7 MW (30 MMBtu/hr) or greater, shall not exhibit opacity greater than 20%, 6-minute average, except as specified.	§ 60.45c(a) § 60.45c(a)(8) § 60.47c(a) [G]§ 60.47c(a)(1) [G]§ 60.47c(a)(2) § 60.47c(a)(3)	§ 60.47c(a) [G]§ 60.48c(f) § 60.48c(g)(1) § 60.48c(g)(2) § 60.48c(g)(3) § 60.48c(i)	[G]§ 60.48c(a) § 60.48c(b) [G]§ 60.48c(c) § 60.48c(j)
B24LOAD01	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt from the requirements of this division, except as specified.	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None
B24TANK01A	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(6)(A) § 115.118(a)(7)	None
B322ENG01A	EU	R7ICI-2	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5),	None	§ 117.340(j) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
B322ENG01 A	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 4.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b) § 60.4243(b)(2)(i) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	§ 60.4245(d) [G]§ 60.4245(e)
B322ENG01 A	EU	60JJJJ	NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a NO _x emission limit of 2.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b) § 60.4243(b)(2)(i) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	§ 60.4245(d) [G]§ 60.4245(e)
B322ENG01 A	EU	60JJJJ	VOC	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1	Owners and operators of stationary emergency SI	§ 60.4237(b) § 60.4243(b)(2)(i)	§ 60.4243(b)(2)(i) § 60.4245(a)(1)	§ 60.4245(d) [G]§ 60.4245(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a VOC emission limit of 1.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(f) § 60.4244(g)	§ 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	
B322ENG01 A	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
B329ENG01 A	EU	R7ICI-2	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas	None	§ 117.340(j) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
B329ENG01 A	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 4.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b) § 60.4243(b)(2)(i) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	§ 60.4245(d) [G]§ 60.4245(e)
B329ENG01 A	EU	60JJJJ	NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a NO _x emission limit of 2.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b) § 60.4243(b)(2)(i) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	§ 60.4245(d) [G]§ 60.4245(e)
B329ENG01 A	EU	60JJJJ	VOC	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234	Owners and operators of stationary emergency SI ICE with a maximum	§ 60.4237(b) § 60.4243(b)(2)(i) § 60.4243(f)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2)	§ 60.4245(d) [G]§ 60.4245(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a VOC emission limit of 1.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(f) § 60.4244(g)	§ 60.4245(a)(4) § 60.4245(b)	
B329ENG01A	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
B329TANK01	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
B32GEN09	EU	R7201-2	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11)	Units exempted from the provisions of this	None	§ 117.340(j) [G]§ 117.345(f)(10)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 117.310(f)	division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)		[G]§ 117.345(f)(6)	
B32GEN09	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B32GEN09	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B32GEN09	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B32GEN09	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
B37GEN03	EU	R7201-2	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						§117.303(a)(11)(A)-(B)			
B37GEN03	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B37GEN03	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 75 KW and less than or equal to 560 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NOx emission limit of 4.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B37GEN03	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2)	Owners and operators of emergency stationary CI	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
B37GEN03	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
B420BLR02	EU	R7ICI-B420	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(C)	An owner or operator may not use the alternative methods	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(1)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(f)(9)	[G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B420BLR02	EU	R7ICI-B420	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B420WOOD01	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B421BLR01	EU	R7ICI-B421	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(1)(C) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B421BLR01	EU	R7ICI-B421	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B) § 117.310(c)(3) § 117.8120	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.8000(b) § 117.8000(c)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B)		[G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
B46GEN01	EU	R7201-2	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
B46GEN01	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
B46GEN01	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
B46GEN01	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 89.112(a)	displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
B46GEN01	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
B48GEN01	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B48GEN02	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						minute period.	Summary		
B48GEN03	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B7GEN02	EU	R7ICI-2	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(6)	None
B7GEN02	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 4.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b)	§ 60.4243(a)(1) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	[G]§ 60.4245(e)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
B7GEN02	EU	60JJJJ	NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a NO _x emission limit of 2.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b)	§ 60.4243(a)(1) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	[G]§ 60.4245(e)
B7GEN02	EU	60JJJJ	VOC	40 CFR Part 60, Subpart JJJJ	§ 60.4233(e)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(1) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than or equal to 130 HP and were manufactured on or after 01/01/2009 must comply with a VOC emission limit of 1.0 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(b)	§ 60.4243(a)(1) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(3) § 60.4245(b)	[G]§ 60.4245(e)
B7GEN02	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						ignition engines as applicable. No further requirements apply for such engines under this part.			
B9AC01	EP	R5122	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	None	§ 115.126 § 115.126(4)	None
B9AC02	EP	R5122	VOC	30 TAC Chapter 115, Vent Gas Controls	§ 115.127(a)(2)(A) [G]§ 115.122(a)(4) § 115.127(a)(2)	A vent gas stream having a combined weight of volatile organic compounds (VOC) < 100 lbs (45.4 kg) in any continuous 24-hour period is exempt from the requirements of § 115.121(a)(1).	None	§ 115.126 § 115.126(4)	None
B9PAINT01	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B9PLAT	PRO	63WWW WWW	112(B) HAPS	40 CFR Part 63, Subpart WWWWWW	[G]§ 63.11507(g) § 63.11508(b) § 63.11508(d)(1) § 63.11508(d)(8)(i) § 63.11510	Owners or operators of new or existing plating and polishing process units that contain, apply, or emit one or more of the plating and polishing metal HAP, must	None	§ 63.11508(d)(2) § 63.11508(d)(8)(ii) § 63.11509(c)(6) § 63.11509(c)(7) [G]§ 63.11509(e) § 63.11509(f)	§ 63.11508(a) § 63.11508(d)(2) § 63.11508(d)(8)(ii) § 63.11509(a) [G]§ 63.11509(b) § 63.11509(c)(6) § 63.11509(c)(7)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						implement the applicable management practices in § 63.11507(g)(1) - (12)			§ 63.11509(d)
B9WOOD01	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B9WOOD02	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
B9WOOD03	EP	R1111A	OPACITY	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(A) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 30% averaged over a six minute period.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
BSTART-1	EU	R7201-1	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
BSTART-1	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 3.5 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
BSTART-1	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than 560 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with an NMHC+NO _x emission limit of 6.4 g/KW-hr, as stated in 40 CFR	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						60.4202(a)(2) and 40 CFR 89.112(a).			
BSTART-1	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 130 KW and less than or equal to 2237 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.20 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
BSTART-1	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						part.			
GRPGEN	EU	R7ICI-1	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D) [G]§ 117.310(f)	Units exempted from the provisions of this division, except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GRPGEN2	EU	R7201-2	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)			
GRPGEN2	EU	60III	CO	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
GRPGEN2	EU	60III	NMHC and NO _x	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr, as stated in 40	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						CFR 60.4202(a)(2) and 40 CFR 89.112(a).			
GRPGEN2	EU	60III	PM	40 CFR Part 60, Subpart III	§ 60.4205(b) § 60.4202(a)(2) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) [G]§ 60.4211(f) § 60.4218 § 89.112(a)	Owners and operators of emergency stationary CI ICE, that are not fire pump engines, with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a PM emission limit of 0.40 g/KW-hr, as stated in 40 CFR 60.4202(a)(2) and 40 CFR 89.112(a).	§ 60.4209(a)	§ 60.4214(b)	[G]§ 60.4214(d)
GRPGEN2	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						part.			
GRPGEN3	EU	R7201-3	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(D) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGEN3	EU	R7201-3	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(1)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)	[G]§ 117.345(f)(10) § 117.345(f)(9)	[G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGEN4	EU	R7201-3	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(D) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(h)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					[G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGEN4	EU	R7201-3	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(10) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		[G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGEN4	EU	63ZZZZ-1	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6603(a)- Table2d.1 § 63.6595(a)(1) § 63.6605(a) § 63.6605(b) § 63.6625(e) § 63.6625(h) § 63.6625(i) § 63.6640(b)	For each existing non-emergency, non-black start CI stationary RICE with a site rating less than or equal to 300 HP, located at an area source, you must comply with the requirements as specified in Table 2d.1.a-c.	§ 63.6625(i) § 63.6640(a) § 63.6640(a)- Table6.9.a.i § 63.6640(a)- Table6.9.a.ii § 63.6640(b)	§ 63.6625(i) § 63.6655(a) § 63.6655(a)(1) § 63.6655(d) § 63.6655(e) § 63.6660(a) § 63.6660(b) § 63.6660(c)	§ 63.6640(b) § 63.6640(e) § 63.6650(f)
GRPGEN5	EU	R7201-4	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(9)(E)(iv) (III) § 117.310(b) [G]§ 117.310(e)(1)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(10) § 117.345(f)(3) § 117.345(f)(3)(B) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) § 117.340(p)(2)(D) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) [G]§ 117.310(f) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(2)(C) § 117.340(p)(3)	but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	§ 117.340(h) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.340(p)(2)(A) § 117.340(p)(2)(B) § 117.340(p)(2)(C) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii) § 117.8000(b) § 117.8000(c) § 117.8000(c)(1) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGEN5	EU	R7201-4	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(B)	CO emissions must not exceed 400 ppmv at 3.0% O 2, dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(d) § 117.335(e) § 117.335(g) § 117.340(a) § 117.340(h) § 117.345(f)(3) § 117.345(f)(3)(A) § 117.345(f)(3)(A)(ii)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(10) § 117.345(f)(9)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8000(b) § 117.8000(c) § 117.8000(c)(2) § 117.8000(c)(3) § 117.8000(c)(5) § 117.8000(c)(6) [G]§ 117.8000(d) § 117.8120 § 117.8120(2) [G]§ 117.8120(2)(A) § 117.8120(2)(B) § 117.8140(a) § 117.8140(a)(1) § 117.8140(a)(2) § 117.8140(a)(2)(A) [G]§ 117.8140(a)(2)(B) § 117.8140(b)		§ 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)
GRPGEN5	EU	60III-2	CO	40 CFR Part 60, Subpart III	§ 60.4204(b) § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218 § 89.112(a)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW and less than 130 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year and later must comply with a CO emission limit of 5.0 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a) and 40 CFR 1039.102 and 40 CFR 1039.101.	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
GRPGEN5	EU	60III-2	NMHC and NO _x	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218 § 89.112(a)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year must comply with an NMHC+NO _x emission limit of 7.5 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a).	None	None	None
GRPGEN5	EU	60III-2	PM	40 CFR Part 60, Subpart IIII	§ 60.4204(b) § 60.4201(a) § 60.4206 § 60.4207(b) [G]§ 60.4211(a) § 60.4211(c) § 60.4218 § 89.112(a)	Owners and operators of non-emergency stationary CI ICE with a maximum engine power greater than or equal to 37 KW and less than 75 KW and a displacement of less than 10 liters per cylinder and is a 2007 model year must comply with a PM emission limit of 0.40 g/KW-hr as stated in 40 CFR 60.4201(a) and 40 CFR 89.112(a).	None	None	None
GRPGEN5	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part	None	None	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.			
GRPGEN-B	EU	R7ICI-1	EXEMPT	30 TAC Chapter 117, Subchapter B	[G]§ 117.303(a)(11) [G]§ 117.310(f)	Units exempted from the provisions of this division except as specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1) and 117.354(a)(5) include new, modified, reconstructed, or relocated stationary diesel engine placed into service on or after October 1, 2001, that operates less than 100 hours per year, based on a rolling 12-month average, in other than emergency situations; and meets the requirements for non-road engines as specified. §117.303(a)(11)(A)-(B)	None	§ 117.340(j) [G]§ 117.345(f)(10) [G]§ 117.345(f)(6)	None
GRPGEN-C	EU	R7ICI-2	EXEMPT	30 TAC Chapter 117, Subchapter B	§ 117.303(a)(6)(D)	Units exempted from the provisions of this division, except as	None	§ 117.340(j) [G]§ 117.345(f)(6)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						specified in §§117.310(f), 117.340(j), 117.345(f)(6) and (10), 117.350(c)(1), and 117.354(a)(5), include stationary gas turbines and stationary internal combustion engines that are used exclusively in emergency situations, except that operation for testing or maintenance purposes is allowed for up to 52 hours per year, based on a rolling 12-month average.			
GRPGEN-C	EU	60JJJJ	CO	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g) § 60.4246	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than 25 HP and less than 130 HP and were manufactured on or after 01/01/2009 must comply with a CO emission limit of 387 g/HP-hr, as listed in Table 1 to this subpart.	§ 60.4237(c) § 60.4243(b)(2)(i) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(e)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	§ 60.4245(d)
GRPGEN-C	EU	60JJJJ	HC and NO _x	40 CFR Part 60, Subpart JJJJ	§ 60.4233(d)-Table1 § 60.4234 § 60.4243(b) § 60.4243(b)(2) § 60.4243(b)(2)(i) [G]§ 60.4243(d) § 60.4243(g)	Owners and operators of stationary emergency SI ICE with a maximum engine power greater than 25 HP and less than 130 HP and were manufactured on or after 01/01/2009 must comply	§ 60.4237(c) § 60.4243(b)(2)(i) § 60.4243(f) § 60.4244(a) § 60.4244(b) § 60.4244(c) § 60.4244(d)	§ 60.4243(b)(2)(i) § 60.4245(a)(1) § 60.4245(a)(2) § 60.4245(a)(4) § 60.4245(b)	§ 60.4245(d)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
					§ 60.4246	with an HC+NOx emission limit of 10 g/HP-hr, as listed in Table 1 to this subpart.			
GRPGEN-C	EU	63ZZZZ	112(B) HAPS	40 CFR Part 63, Subpart ZZZZ	§ 63.6590(c)	Stationary RICE subject to Regulations under 40 CFR Part 60. An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 subpart JJJJ, for spark ignition engines as applicable. No further requirements apply for such engines under this part.	None	None	None
GRPTANK	EU	R5112	VOC	30 TAC Chapter 115, Storage of VOCs	§ 115.111(a)(1)	Except as provided in § 115.118, a storage tank storing VOC with a true vapor pressure less than 1.5 psia is exempt from the requirements of this division.	[G]§ 115.117	§ 115.118(a)(1) § 115.118(a)(5) § 115.118(a)(7)	None
GRPTANK2	EU	R5211	VOC	30 TAC Chapter 115, Loading and Unloading of VOC	§ 115.217(a)(1) § 115.212(a)(2) § 115.214(a)(1)(B) § 115.214(a)(1)(D) § 115.214(a)(1)(D)(i)	Vapor pressure (at land-based operations). All land-based loading and unloading of VOC with a true vapor pressure less than 0.5 psia is exempt	§ 115.214(a)(1)(A) § 115.214(a)(1)(A)(i) § 115.215 § 115.215(4)	§ 115.216 § 115.216(2) § 115.216(3)(B)	None

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
						from the requirements of this division, except as specified.			
GRPTBN	EP	R1111	PM (OPACITY)	30 TAC Chapter 111, Visible Emissions	§ 111.111(a)(1)(B) § 111.111(a)(1)(E)	Visible emissions from any stationary vent shall not exceed an opacity of 20% averaged over a six minute period for any source on which construction was begun after January 31, 1972.	[G]§ 111.111(a)(1)(F) ** See Periodic Monitoring Summary	None	None
GRPTBN	EU	R-7201	NO _x	30 TAC Chapter 117, Subchapter B	§ 117.310(d)(3) § 117.310(a) § 117.310(a)(10)(B) § 117.310(b) [G]§ 117.310(e)(1) § 117.310(e)(2) [G]§ 117.310(e)(3) § 117.310(e)(4) § 117.340(f)(1) § 117.340(l)(2) § 117.340(p)(1) § 117.340(p)(3)	An owner or operator may not use the alternative methods specified in §§ 117.315, 117.323 and 117.9800 to comply with the NO _x emission specifications but shall use the mass emissions cap and trade program in Chapter 101, Subchapter H, Division 3, except that electric generating facilities must also comply with the daily and 30-day system cap emission limitations of § 117.320. An owner or operator may use the alternative methods specified in § 117.9800 to comply with § 117.320.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(g) § 117.340(a) § 117.340(c)(1) [G]§ 117.340(c)(3) [G]§ 117.340(f)(2) § 117.340(l)(2) § 117.340(o)(1) § 117.340(p)(1) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) § 117.8100(a)(1)(B)(i)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(3) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) § 117.8010(2)(C) § 117.8010(2)(D) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							i) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6)		
GRPTBN	EU	R-7201	CO	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(1) § 117.310(c)(1)(A) § 117.340(f)(1)	CO emissions must not exceed 400 ppmv at 3.0% O ₂ , dry basis.	[G]§ 117.335(a)(1) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(f) § 117.335(f)(3) § 117.335(g) § 117.340(a) § 117.340(e) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)(i) i)	§ 117.345(a) § 117.345(f) § 117.345(f)(1) [G]§ 117.345(f)(2) § 117.345(f)(7) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3) § 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 117.8100(a)(1)(B)(i) ii) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8120 § 117.8120(1) § 117.8120(1)(A)		§ 117.8100(c)
GRPTBN	EU	R-7201	NH ₃	30 TAC Chapter 117, Subchapter B	§ 117.310(c)(2) § 117.310(c)(2)(B) § 117.340(f)(1)	For stationary gas turbines that inject urea or ammonia into the exhaust stream for NO _x control, ammonia emissions must not exceed 10 ppmv at 15% O ₂ , dry.	§ 117.335(a)(2) § 117.335(a)(4) § 117.335(b) § 117.335(c) § 117.335(d) § 117.335(g) § 117.340(d) [G]§ 117.340(f)(2) § 117.8100(a) § 117.8100(a)(1) § 117.8100(a)(1)(A) § 117.8100(a)(1)(B) § 117.8100(a)(1)(B)	§ 117.345(a) § 117.345(f) § 117.345(f)(11) [G]§ 117.345(f)(2) § 117.345(f)(8) § 117.345(f)(9) § 117.8100(a)(5)(C)	§ 117.335(b) § 117.335(g) [G]§ 117.345(b) [G]§ 117.345(c) § 117.345(d) § 117.345(d)(2) § 117.345(d)(3) § 117.345(d)(4) § 117.345(d)(5) § 117.8010 [G]§ 117.8010(1) § 117.8010(2) § 117.8010(2)(A) § 117.8010(2)(B) [G]§ 117.8010(3)

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							117.8100(a)(1)(B)(i) i) § 117.8100(a)(1)(C) § 117.8100(a)(2) [G]§ 117.8100(a)(3) § 117.8100(a)(4) § 117.8100(a)(5) § 117.8100(a)(5)(A) § 117.8100(a)(5)(B) [G]§ 117.8100(a)(5)(D) [G]§ 117.8100(a)(5)(E) § 117.8100(a)(6) § 117.8130 § 117.8130(4)		§ 117.8010(4) [G]§ 117.8010(5) § 117.8010(6) [G]§ 117.8010(7) [G]§ 117.8010(8) § 117.8100(c)
GRPTBN	EU	60KKKK	NOx	40 CFR Part 60, Subpart KKKK	§ 60.4320(a)-Table 1 § 60.4320(a) § 60.4320(b) § 60.4325 § 60.4333(a) § 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) § 60.4335(b)(4) [G]§ 60.4345	New turbine firing natural gas with a heat input at peak load greater than 50 MMBtu/h and less than or equal to 850 MMBtu/h must meet the nitrogen oxides emission standard of 150 ng/J of useful output (1.2 lb/MWh).	§ 60.4335(b)(1) § 60.4335(b)(2) § 60.4335(b)(3) § 60.4335(b)(4) [G]§ 60.4345 § 60.4350(a) § 60.4350(b) § 60.4350(c) § 60.4350(d) § 60.4350(e) § 60.4350(f) § 60.4350(f)(2) § 60.4350(h) [G]§ 60.4400(a) § 60.4400(b) § 60.4400(b)(1) § 60.4400(b)(2)	[G]§ 60.4345 § 60.4350(b)	[G]§ 60.4345 § 60.4350(d) § 60.4375(a) § 60.4380 [G]§ 60.4380(b) § 60.4395

Applicable Requirements Summary

Unit Group Process ID No.	Unit Group Process Type	SOP Index No.	Pollutant	State Rule or Federal Regulation Name	Emission Limitation, Standard or Equipment Specification Citation	Textual Description (See Special Term and Condition 1.B.)	Monitoring And Testing Requirements	Recordkeeping Requirements (30 TAC § 122.144)	Reporting Requirements (30 TAC § 122.145)
							§ 60.4400(b)(4) § 60.4400(b)(5) § 60.4400(b)(6) [G]§ 60.4405		
GRPTBN	EU	60KKKK	SO ₂	40 CFR Part 60, Subpart KKKK	§ 60.4330(a)(2) § 60.4333(a)	You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO ₂ /J (0.060 lb SO ₂ /MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.	§ 60.4365 § 60.4365(b) § 60.4415(a) § 60.4415(a)(1) § 60.4415(a)(1)(ii)	§ 60.4365(b)	§ 60.4375(a)

Additional Monitoring Requirements

Periodic Monitoring Summary 81

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-2A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-2A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2
Pollutant: SO ₂	Main Standard: § 112.9(c)
Monitoring Information	
Indicator: Sulfur content of fuel	
Minimum Frequency: Each fuel delivery	
Averaging Period: N/A	
Deviation Limit: Sulfur content of fuel greater than 0.3% by weight.	
Periodic Monitoring Text: Each delivery of diesel fuel shall have a fuel supplier certification or laboratory analysis stating that the fuel sulfur content is less than 0.3% by weight.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-3A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-3A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2
Pollutant: SO _x	Main Standard: § 112.9(c)
Monitoring Information	
Indicator: Sulfur content of fuel	
Minimum Frequency: Each fuel delivery	
Averaging Period: N/A	
Deviation Limit: Liquid fuel shall not contain more than 0.3% by weight sulfur.	
Periodic Monitoring Text: Each delivery of diesel fuel shall have a fuel supplier certification or laboratory analysis stating that the fuel sulfur content is less than 0.3% by weight.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-4A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-4A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2
Pollutant: SO ₂	Main Standard: § 112.9(c)
Monitoring Information	
Indicator: Sulfur content of fuel	
Minimum Frequency: Each fuel delivery	
Averaging Period: N/A	
Deviation Limit: Sulfur content of fuel greater than 0.3% by weight.	
Periodic Monitoring Text: Each delivery of diesel fuel shall have a fuel supplier certification or laboratory analysis stating that the fuel sulfur content is less than 0.3% by weight.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-5A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 20% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B24-5A	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 112, Sulfur Compounds	SOP Index No.: REG2
Pollutant: SO ₂	Main Standard: § 112.9(c)
Monitoring Information	
Indicator: Sulfur content of fuel	
Minimum Frequency: Each fuel delivery	
Averaging Period: N/A	
Deviation Limit: Sulfur content of fuel greater than 0.3% by weight.	
Periodic Monitoring Text: Each delivery of diesel fuel shall have a fuel supplier certification or laboratory analysis stating that the fuel sulfur content is less than 0.3% by weight.	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B420WOOD01	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B48GEN01	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B48GEN02	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B48GEN03	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B9PAINT01	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B9WOOD01	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B9WOOD02	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: B9WOOD03	
Control Device ID No.: N/A	Control Device Type: N/A
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111A
Pollutant: OPACITY	Main Standard: § 111.111(a)(1)(A)
Monitoring Information	
Indicator: Visible Emissions	
Minimum Frequency: once per calendar quarter	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 30% averaged over a six-minute period.	
<p>Periodic Monitoring Text: Visible emissions observations shall be made and recorded. Note that to properly determine the presence of visible emissions, all sources must be in clear view of the observer. The observer shall be at least 15 feet, but not more than 0.25 miles, away from the emission source during the observation. The observer shall select a position where the sun is not directly in the observer's eyes. If the observations cannot be conducted due to weather conditions, the date, time, and specific weather conditions shall be recorded. When condensed water vapor is present within the plume, as it emerges from the emissions outlet, observations must be made beyond the point in the plume at which condensed water vapor is no longer visible. When water vapor within the plume condenses and becomes visible at a distance from the emissions outlet, the observation shall be evaluated at the outlet prior to condensation of water vapor.</p> <p>If visible emissions are observed, the permit holder shall report a deviation. As an alternative, the permit holder may determine the opacity consistent with Test Method 9, as soon as practicable, but no later than 24 hours after observing visible emissions. If the result of the Test Method 9 is opacity above the opacity limit in the applicable requirement, the permit holder shall report a deviation.</p>	

Periodic Monitoring Summary

Unit/Group/Process Information	
ID No.: GRPTBN	
Control Device ID No.: T1SCR	Control Device Type: Selective Catalytic Reduction (SCR)
Control Device ID No.: T2SCR	Control Device Type: Selective Catalytic Reduction (SCR)
Applicable Regulatory Requirement	
Name: 30 TAC Chapter 111, Visible Emissions	SOP Index No.: R1111
Pollutant: PM (OPACITY)	Main Standard: § 111.111(a)(1)(B)
Monitoring Information	
Indicator: Fuel Type	
Minimum Frequency: Annually or at any time an alternate fuel is used	
Averaging Period: n/a	
Deviation Limit: Opacity greater than 20% averaged over six-minute period.	
<p>Periodic Monitoring Text: Record the type of fuel used by the unit. If an alternate fuel is fired, either alone or in combination with the specified gas, for a period greater than or equal to 24 consecutive hours it shall be considered and reported as a deviation or the permit holder shall conduct an observation of the stationary vent for each such period to determine if visible emissions are observed. Any time an alternate fuel is fired for a period of greater than 7 consecutive days then visible emissions observations will be conducted no less than once per week. Documentation of all observations shall be maintained. If visible emissions are present during the firing of an alternate fuel, the permit holder shall either list this occurrence as a deviation or the permit holder may determine the opacity consistent with Test Method 9. Any opacity readings that are above the opacity limit from the underlying applicable requirement shall be reported as a deviation.</p>	

Permit Shield

Permit Shield 99

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
B24-2A	N/A	40 CFR Part 64, Compliance Assurance Monitoring	The boiler's potential to emit is limited to below major source level before control.
B24-4A	N/A	40 CFR Part 60, Subpart Dc	The unit, which has a maximum design heat input capacity between 10 and 100 MMBtu/hr, was constructed prior to June 9, 1989, and has not been modified or reconstructed since that time.
B24-4A	N/A	40 CFR Part 64, Compliance Assurance Monitoring	The boiler's potential to emit is limited to below major source level before control.
B24-5A	N/A	40 CFR Part 64, Compliance Assurance Monitoring	The boiler's potential to emit is limited to below major source level before control.
B24TANK01A	N/A	40 CFR Part 60, Subpart Kb	The liquid stored in this unit, which has a capacity of greater than 151 cubic meters (39,900 gallons), has a maximum true vapor pressure less than 3.5 kilopascals (0.5 psia).
B326APW01	N/A	30 TAC Chapter 115, Degreasing Processes	The unit is a remote reservoir cold cleaner that uses a solvent with a true vapor pressure less than 0.6 psia at 100 degrees Fahrenheit with a drain area less than 16 square inches, and the waste solvent is disposed in enclosed containers.
B326TANK03	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank capacity is less than or equal to 1,000 gallons (3,785 L).
B326TANK03	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,800 gallons).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
B329TANK01	N/A	40 CFR Part 60, Subpart Kb	This unit has a capacity of less than 75 cubic meters (19,800 gallons).
B32TANK04	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,800 gallons).
B417FUEL01	N/A	40 CFR Part 60, Subpart Kb	This unit has a capacity of less than 75 cubic meters (19,800 gallons).
B417OWS01	N/A	30 TAC Chapter 115, Water Separation	This unit is not subject to Chapter 115 Division 3 Water Separation because the separator is designed solely to capture stormwater, spills, or exterior cleanup waters and is fully covered.
B417PW01	N/A	30 TAC Chapter 115, Degreasing Processes	The unit is a remote reservoir cold cleaner that uses a solvent with a true vapor pressure less than 0.6 psia at 100 degrees Fahrenheit with a drain area less than 16 square inches, and the waste solvent is disposed in enclosed containers.
B42TANK02	N/A	30 TAC Chapter 115, Storage of VOCs	Storage tank capacity is less than or equal to 1,000 gallons (3,785 L).
B42TANK02	N/A	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,800).
GRPTANK	B326TANK01, B48TANK01, B48TANK02	40 CFR Part 60, Subpart Kb	Each unit in this group has a capacity of less than 75 cubic meters (19,800 gallons).

Permit Shield

The Executive Director of the TCEQ has determined that the permit holder is not required to comply with the specific regulation(s) identified for each emission unit, group, or process in this table.

Unit/Group/Process		Regulation	Basis of Determination
ID No.	Group/Inclusive Units		
GRPTANK2	B10TANK01, B15TANK01, B17TANK01, B25TANK01, B30ATANK01, B32TANK01, B32TANK02, B32TANK03, B343TANK01, B347TANK01, B37TANK01, B37TANK02, B3TANK01, B46TANK01, B48TANK03, B48TANK04, B48TANK05, B9TANK01	30 TAC Chapter 115, Storage of VOCs	Storage tank capacity is less than or equal to 1,000 gallons (3,785 L).
GRPTANK2	B10TANK01, B15TANK01, B17TANK01, B25TANK01, B30ATANK01, B32TANK01, B32TANK02, B32TANK03, B343TANK01, B347TANK01, B37TANK01, B37TANK02, B3TANK01, B46TANK01, B48TANK03, B48TANK04, B48TANK05, B9TANK01	40 CFR Part 60, Subpart Kb	Tank capacity is less than 75 cubic meters (19,800 gallons).
PROPAINT	N/A	30 TAC Chapter 115, Surface Coating Operations	PROPAINT is solely engaged in research and development activities associated with NASA manned space program. Any solvents used in this process for thinning and/or cleanup are also exempt.
PROPAINT	N/A	40 CFR Part 63, Subpart GG	The units do not engage in the manufacture or rework of commercial, civil, or military aerospace vehicles or components. These units are solely engaged in research and development activities associated with NASA manned space program.

New Source Review Authorization References

New Source Review Authorization References.....	103
New Source Review Authorization References by Emission Unit	105

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Title 30 TAC Chapter 116 Permits, Special Permits, and Other Authorizations (Other Than Permits By Rule, PSD Permits, or NA Permits) for the Application Area.	
Authorization No.: 114721	Issuance Date: 08/18/2014
Authorization No.: 130148	Issuance Date: 03/16/2015
Authorization No.: 19211	Issuance Date: 10/17/2014
Authorization No.: 53868	Issuance Date: 08/09/2012
Authorization No.: 76247	Issuance Date: 08/07/2015
Permits By Rule (30 TAC Chapter 106) for the Application Area	
Number: 106.102	Version No./Date: 09/04/2000
Number: 106.122	Version No./Date: 09/04/2000
Number: 106.124	Version No./Date: 09/04/2000
Number: 106.183	Version No./Date: 09/04/2000
Number: 106.227	Version No./Date: 09/04/2000
Number: 106.242	Version No./Date: 09/04/2000
Number: 106.261	Version No./Date: 11/01/2003
Number: 106.262	Version No./Date: 12/24/1998
Number: 106.262	Version No./Date: 09/04/2000
Number: 106.262	Version No./Date: 11/01/2003
Number: 106.263	Version No./Date: 11/01/2001
Number: 106.265	Version No./Date: 09/04/2000
Number: 106.371	Version No./Date: 09/04/2000
Number: 106.375	Version No./Date: 03/14/1997
Number: 106.412	Version No./Date: 09/04/2000
Number: 106.418	Version No./Date: 09/04/2000
Number: 106.454	Version No./Date: 07/08/1998
Number: 106.454	Version No./Date: 11/01/2001
Number: 106.472	Version No./Date: 03/14/1997
Number: 106.472	Version No./Date: 09/04/2000
Number: 106.478	Version No./Date: 03/14/1997
Number: 106.478	Version No./Date: 09/04/2000

New Source Review Authorization References

The New Source Review authorizations listed in the table below are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Number: 106.511	Version No./Date: 06/18/1997
Number: 106.511	Version No./Date: 09/04/2000
Number: 5	Version No./Date: 12/01/1972
Number: 5	Version No./Date: 09/23/1982
Number: 5	Version No./Date: 09/12/1989
Number: 5	Version No./Date: 07/20/1992
Number: 5	Version No./Date: 05/04/1994
Number: 41	Version No./Date: 07/20/1992
Number: 51	Version No./Date: 11/05/1986
Number: 51	Version No./Date: 08/30/1988
Number: 51	Version No./Date: 07/20/1992
Number: 51	Version No./Date: 05/04/1994
Number: 61	Version No./Date: 07/20/1992
Number: 75	Version No./Date: 09/12/1989
Number: 124	Version No./Date: 05/12/1981

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
B10GEN02	STATIONARY EMERGENCY GENERATOR	106.511/06/18/1997
B10TANK01	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B15GEN01	STATIONARY EMERGENCY GENERATOR	106.511/06/18/1997
B15TANK01	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B17GEN02	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000
B17TANK01	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B21GEN01	EMERGENCY DIESEL GENERATOR	106.511/09/04/2000
B221ENG01	BUILDING 221 ENGINE 1	106.511/09/04/2000
B223ENG02	BUILDING 223, ENGINE 2	106.511/09/04/2000
B24-2A	BUILDING 24 BOILER 2A	19211
B24-3A	BUILDING 24 BOILER 3A	114721
B24-4A	BUILDING 24 BOILER 4A	19211
B24-5A	BOILER B24-5A	76247
B24LOAD01	DIESEL LOADING	106.472/09/04/2000
B24TANK01A	BUILDING 24 DIESEL TANK	106.478/09/04/2000
B25GEN02	BUILDING 25 GENERATOR 2	106.511/09/04/2000
B25TANK01	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B30AGEN02	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000
B30ATANK01	DIESEL FUEL STORAGE TANK	106.472/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
B322ENG01A	EMERGENCY NATURAL GAS FIRED ENGINE	106.511/09/04/2000
B326APW01	BUILDING 326 PARTS WASHER	106.454/11/01/2001
B326TANK01	BUILDING 326 DIESEL TANK	51/08/30/1988
B326TANK03	GASOLINE STORAGE TANK	106.478/09/04/2000
B329ENG01A	EMERGENCY NATURAL GAS FIRED ENGINE	106.511/09/04/2000
B329TANK01	BUILDING 329 WASTEWATER TANK	106.472/09/04/2000
B32GEN06	STATIONARY EMERGENCY GENERATOR	106.511/06/18/1997
B32GEN07	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000
B32GEN08	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000
B32GEN09	BUILDING 32 GENERATOR 9	106.511/09/04/2000
B32TANK01	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B32TANK02	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B32TANK03	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B32TANK04	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B343GEN01	BUILDING 343 GENERATOR 1	106.511/09/04/2000
B343TANK01	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B347GEN01	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000
B347TANK01	DIESEL FUEL STORAGE TANK	106.478/09/04/2000
B37GEN03	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
B37GEN04	STATIONARY EMERGENCY GENERATOR	106.511/09/04/2000
B37TANK01	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B37TANK02	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B3GEN01	STATIONARY EMERGENCY GENERATOR	106.511/06/18/1997
B3TANK01	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B417FUEL01	ETHANOL E85 FLEET FUEL DISPENSING UNIT	106.412/09/04/2000
B417OWS01	OIL/WATER SEPARATOR	61/07/20/1992
B417PW01	BUILDING 417 PARTS WASHER	106.454/11/01/2001
B420BLR02	BOILER	106.183/09/04/2000
B420WOOD01	BUILDING 420 DUST COLLECTION SYSTEM	124/05/12/1981
B421BLR01	BOILER	106.183/09/04/2000
B42TANK02	DIESEL FUEL STORAGE TANK	106.478/09/04/2000
B46GEN01	BUILDING 46 STATIONARY EMERGENCY GENERATOR #1	106.511/09/04/2000
B46TANK01	DIESEL FUEL STORAGE TANK	106.472/09/04/2000
B48GEN01	BUILDING 48 GENERATOR 1	5/12/01/1972
B48GEN02	BUILDING 48 GENERATOR 2	5/12/01/1972
B48GEN03	BUILDING 48 GENERATOR 3	5/12/01/1972
B48GEN07	BUILDING 48 GENERATOR 7	5/09/23/1982
B48GEN09	BUILDING 48 GENERATOR 9	5/07/20/1992

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
B48TANK01	BUILDING 48 DIESEL TANK NO. 1	51/07/20/1992
B48TANK02	BUILDING 48 DIESEL TANK NO. 2	51/07/20/1992
B48TANK03	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B48TANK04	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B48TANK05	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B7GEN02	BUILDING 7 GENERATOR #2	106.511/09/04/2000
B9AC01	BUILDING 9 AUTOCLAVE 1	106.124/09/04/2000
B9AC02	BUILDING 9 AUTOCLAVE 2	106.124/09/04/2000
B9GEN01	STATIONARY EMERGENCY GENERATOR	106.511/06/18/1997
B9PAINT01	BUILDING 9 PAINT BOOTH	75/09/12/1989
B9PLAT	METAL FINISHING SHOP	106.375/03/14/1997
B9TANK01	DIESEL FUEL STORAGE TANK	106.472/03/14/1997
B9WOOD01	BUILDING 9 DUST COLLECTION SYSTEM	124/05/12/1981
B9WOOD02	BUILDIGN 9 DUST COLLECTION SYSTEM	124/05/12/1981
B9WOOD03	BUILDING 9 DUST COLLECTION SYSTEM	124/05/12/1981
BSTART-1	BLACK START DIESEL GENERATOR	106.511/09/04/2000
PROPAINT	PAINT BOOTH PROCESSES	75/09/12/1989
T-1	NATURAL GAS COMBUSTION TURBINE	130148

New Source Review Authorization References by Emissions Unit

The following is a list of New Source Review (NSR) authorizations for emission units listed elsewhere in this operating permit. The NSR authorizations are applicable requirements under 30 TAC Chapter 122 and enforceable under this operating permit.

Unit/Group/Process ID No.	Emission Unit Name/Description	New Source Review Authorization
T-2	NATURAL GAS COMBUSTION TURBINE	130148

Appendix A

Acronym List	111
--------------------	-----

Acronym List

The following abbreviations or acronyms may be used in this permit:

ACFM	actual cubic feet per minute
AMOC	alternate means of control
ARP	Acid Rain Program
ASTM	American Society of Testing and Materials
B/PA	Beaumont/Port Arthur (nonattainment area)
CAM	Compliance Assurance Monitoring
CD	control device
COMS	continuous opacity monitoring system
CVS	closed-vent system
D/FW	Dallas/Fort Worth (nonattainment area)
DR	Designated Representative
ELP	El Paso (nonattainment area)
EP	emission point
EPA	U.S. Environmental Protection Agency
EU	emission unit
FCAA Amendments	Federal Clean Air Act Amendments
FOP	federal operating permit
GF	grandfathered
gr/100 scf	grains per 100 standard cubic feet
HAP	hazardous air pollutant
H/G/B	Houston/Galveston/Brazoria (nonattainment area)
H ₂ S	hydrogen sulfide
ID No.	identification number
lb/hr	pound(s) per hour
MMBtu/hr	Million British thermal units per hour
MRRT	monitoring, recordkeeping, reporting, and testing
NA	nonattainment
N/A	not applicable
NADB	National Allowance Data Base
NO _x	nitrogen oxides
NSPS	New Source Performance Standard (40 CFR Part 60)
NSR	New Source Review
ORIS	Office of Regulatory Information Systems
Pb	lead
PBR	Permit By Rule
PM	particulate matter
ppmv	parts per million by volume
PSD	prevention of significant deterioration
RO	Responsible Official
SO ₂	sulfur dioxide
TCEQ	Texas Commission on Environmental Quality
TSP	total suspended particulate
TVP	true vapor pressure
U.S.C.	United States Code
VOC	volatile organic compound